



MUNICIPAL CORPORATION OF DELHI  
PUBLIC HEALTH DEPARTMENT, WEST ZONE  
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



Dated: 20/12/22

No. DHO/WZ/2022/D- 3014

HEALTH CERTIFICATE

1. Name of the School ANGEL PUBLIC SCHOOL
2. School address WZ-II, PH.II, OM VIHAR UTTAM NAGAR, NEW DELHI-110059
3. No of shifts MORNING (01) Timing 8.00 AM TO 2.00 PM
4. No of students:- Boys 533 Girls 424 Total 997
5. No of staff:- Gents 06 Ladies 23 Total 29

Accommodation provide for classroom as under:-

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue



*Neelam*  
Dy. Health Officer  
West Zone  
Dy. Health Officer  
West Zone

“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”



DELHI JAL BOARD  
( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL LABORATORY,  
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water sample collected from “Angel Public School” Wz-02 Ph-II A Om Vihar, Uttam Nagar New Delhi - 110059 vide challan No- 224 Dated-10.11.2022.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
<b>PHYSICAL EXAMINATION</b>					
1.	Date of collection	-----	--	--	19.11.2022
2.	Date of Analysis	-----	--	--	21.11.2022
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj
5.	Turbidity	N.T.U.	1.0	5.0	1.12
6.	PH value	-----	6.5	8.5	7.4
7.	Electrical Conductivity	µmho	--	--	266.3
8.	Total dissolved solids	mg/l	500	2000	131
<b>CHEMICAL EXAMINATION</b>					
9.	P <sup>th</sup> Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	66
11.	Total Hardness	mg/l	200	600	112
12.	Calcium Hardness	mg/l	--	--	60
13.	Magnesium Hardness	mg/l	--	--	52
14.	Calcium as Ca	mg/l	75	200	24
15.	Magnesium as Mg	mg/l	30	100	12.48
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	--	NIL
18.	Nitrate as No <sub>3</sub>	mg/l	45	N.R.	3.0
19.	Sulphate	mg/l	200	400	32
20.	Chloride	mg/l	250	1000	14
21.	Dissolved Iron	mg/l	0.3	N.R.	0.04
22.	Fluoride	mg/l	1	1.5	0.06
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	1.25
<b>BACTERIOLOGICAL EXAMINATION</b>					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS : As per tested parameters sample -S1 can be use for drinking purpose.

*Spandey*  
Chemist

*Spandey*  
23/11/22  
Asstt. Chief Water Analyst  
DELHI JAL BOARD  
Govt. of N.C.T. Delhi  
Quality Control Laboratory  
Water Works, Nangloi, Delhi-41